


# Transmission Business Briefing

---



**ATC's service area**



# Our progress in five years

---

## **A more reliable transmission system**

- Invested \$481 million to:
  - Upgrade more than 565 miles of power lines
  - Improve 79 substations
  - Build 75 miles new power lines
  - Connect 1,767 megawatts new generation




## What this work means

---

- ATC now can:
  - Deliver up to 12,765 megawatts to customers in Wisconsin, Michigan and Illinois
  - Maintain 99.96% availability rating
  - Support 828 MW new peak usage
  - Increase import power by 1,000 MW

## How the electric system works

The electric system is comprised of three components: generating plants, transmission lines and distribution facilities. ATC is a public utility that owns and operates the transmission system which carries electricity from generating plants to load centers or areas where a considerable amount of electricity is needed.



# The vital link

# Moving power into or through our system


---



## Specific projects (completed):

- Blackhawk-Colley Road (Rock County)
- Christiana-Kegonsa (Dane County)
- Eau Claire-Arpin (Wood County)
- Kewaunee Area Projects (Kewaunee County)
- Manistique-Hiawatha (Schoolcraft and Mackinac counties)
- North Appleton-Lost Dauphin (Outagamie and Brown counties)
- North Appleton-White Clay (Outagamie and Shawano counties)
- Paris-St. Martins (Kenosha, Racine, and Milwaukee counties)
- Rhinelander Area Projects (Lincoln, Oneida and Langlade counties)
- Wempletown-Paddock (Rock County and northern Illinois)
- Whitewater-Mukwonago (Walworth and Waukesha counties)


# 27 projects completed since 2004



# 10-Year system assessment


---

- ➔ Fifth year of assessment and report
- ➔ Covers years 2005 through 2015
- ➔ Identifies conditions that drive plans for upgrades and expansion
- ➔ Identifies projects needed to improve system adequacy and reliability



# Multi-level planning process

---





# Changes since 2004



<i>Table ES-1</i>		
<i>Summary of American Transmission Co.'s</i>		
<b>2005 Transmission System Assessment</b>		
	<b>2004 Update</b>	<b>2005 Assessment</b>
	(March 2005)	(September 2005)
<b><i>New Transmission Lines Requiring New Right-of-Way</i></b>		
345 kV	8 lines / 340 miles	8 lines / 340 miles
138 kV	17 lines / 95 miles	14 lines / 77 miles
115 kV	3 lines / 32 miles	2 lines / 26 miles
69 kV	7 lines / 53 miles	12 lines / 82 miles
<b><i>Transmission Lines to be Constructed, Rebuilt, Reconductored or Upgraded on Existing Right-of-Way</i></b>		
345 kV	8 lines / 140 miles	5 lines / 114 miles
161 kV	1 / 20 miles	1 / 20 miles
138 kV	49 lines / 889 miles	42 lines / 706 miles
115 kV	4 lines / 78 miles	4 lines / 78 miles
69 kV	11 lines / 80 miles	11 lines / 66 miles
<b><i>New Transformers to be Installed</i></b>		
<b><i>(# of transformers / total increase in capacity)</i></b>	44 transformers / 8,467 MVA	41 transformers / 8,457 MVA
<b><i>New Capacitor Banks to be Installed</i></b>		
<b><i>(# of installations / capacity)</i></b>	24 installations / 1,047 MVAR	35 installations / 1,255 MVAR



## Assessment enhancements and additions

---

- Interactive Web site with links
  - [www.atc10yearplan.com](http://www.atc10yearplan.com)
- Transmission Access Initiative
- 20-year analysis goals
  - Started in 2005 TYA, finish for 2006 TYA
  - System consistency
  - Identify generation sites
- ATC regional studies involvement
- Maintenance projects greater than \$500,000
- Prioritization methodology tool



# Assessment enhancements and additions

---

- **Reactive power analysis**
  - Reduce generation MVar capability by 10%
  - First contingencies
  - No significant impact
- **Multiple outage analysis**
  - Additional steady state and dynamics studies
  - Rechecked critical contingencies
  - Meet national reliability standards with load shedding/operating procedures
- **All projects assessment**
  - 2010 and 2014 studies
  - Project synergy (don't create new problems)

# System expansion drivers

---

- Electric load growth
- Transmission-distribution interconnections
- Transmission service limitations
- New generation
- Transmission service requests
- System repair or replacement
- Economic strategic expansion





# Types of Projects

---

## Line projects

- New line
- Rebuilt line
- Reconductor line
- Uprate line
- Convert voltage

## Substation Projects

- New Substation
- Existing substation expansion
- Equipment additions and replacements

# Project classifications

Project Activity	Planned	Proposed	Provisional
<i>ATC planning work and analysis</i>	Studies completed	Studies are not complete	Studies are not complete
<i>Construction application For regulatory review</i>	Application under review or approved	Application has not been submitted	No action on preparing or submitting an application
<i>Project implementation phase</i>	Project approved and under construction or being engineered for construction	Project identified as preferred solution to transmission issue	Project is placeholder and among several solutions being evaluated and studied
<i>System solution included in power flow models</i>	Project included to show impact on system	Project not included	Project not included

# Load interconnection requests

---

**New** transmission to distribution substations

**Add** transmission to distribution transformers at existing substations

**Replace** transmission to distribution transformers at existing substations

Zone	New	Add	Replace	Total
1	15	13	1	29
2	6	11	2	19
3	49	21	10	80
4	23	34	12	69
5	13	16	2	31
<b>Totals</b>	<b>106</b>	<b>95</b>	<b>27</b>	<b>228</b>




# Generator requests placed in service

---

Date	Requests On-Line	Megawatts
2000	Eden/Little Badger	31
2001	Combined Locks	53
6/1/2003	Pulliam CT, Petenwell/Big Pond	105
3/19/2004	Kewaunee uprate	43
6/1/2004	Kaukauna CT	60
6/15/2004	Riverside	655
5/1/2005	West Campus	150
6/1/2005	Fox Energy	300
6/2/2005	Sheboygan	370
	<b>Total</b>	<b>1,767</b>





**★ = Generation interconnection requests as of July 1, 2005**

# Chronic transmission loading relief incidents - 2004



Limiting Element	Anticipated Element Outage	Total Declarations
Albers-Paris 138 kV	Wempletown-Paddock 345 kV	29
Eau Claire-Arpin 345 kV		10
Highway V-Preble 138 kV	Lost Dauphin-Red Maple 138 kV	29
Oak Creek 345/230 kV transformer	Oak Creek banks T851/T895	24
Stiles-Amberg/Stiles-Crivitz 138 kV	Morgan-Plains 345 kV	154
Stiles-Pioneer 138 kV	White Clay-Morgan 138 kV	19
White Clay-Morgan 138 kV	Pulliam-Stiles 138 kV	22



# Zone 1 – North Central Wisconsin

---

- Growth projections
  - Population: 0.6% from 2005-2010
  - Employment: 1.2% from 2005-2010
- Environmental considerations
  - North: woodlands and lakes
  - South: agricultural
  - National forests and wildlife refuges
- Electricity demand and generation
  - Expected load growth: 2% from 2006-2014  
(2006 peak load is 1,789 MW)
  - Net importer of power during peak demand periods
  - New generation: Weston 4 (550 MW)



# Zone 1 system conditions

---

## ■ 2006

- Low voltages in Rhinelander loop
- Low voltages in Tomah area
- Overloaded facilities for Weston-Sherman St. outage

## ■ 2010

- Same problems as in 2006, but worse if planned and proposed projects are not completed
- Widespread overloaded facilities in Wausau area with addition of Weston G4 without Gardner Park-Central Wisconsin 345 kV line and 115 kV reinforcements



# Zone 1 system conditions

---

- **2014**
  - Emerging overloads to system feeding the Rhineland loop
  - Emerging overloads and low voltages in the Wautoma, Berlin and Ripon areas
  - Additional generation requests in the Wausau or Plover areas may impact transmission system plans



# Zone 1

## 45+ projects 2005-2015

---

Most notable projects include:

### Planned

- 2 Arrowhead-Weston 345 kV line (2006/2008)
- 5 Gardner Park-Central Wisconsin 345 kV line (2009)

### Proposed

- 7 Weston-Sherman St.-Hilltop rebuild (2007)
- 8 Cranberry-Conover 115 kV line (2008)

### Provisional

- 9 Monroe County-Council Creek 161 kV line (2010)

## Zone 2 – Northern Wis./Mich. UP

---

- Growth projections
  - Population: 0.2% from 2005-2010
  - Employment: 1.3% from 2005-2010
- Environmental considerations
  - Heavily forested areas
  - Many lakes, rivers and streams
- Electricity demand and generation
  - Expected load growth: 0.8% from 2006-2014
    - 2006 peak load is 906 MW
  - More generation (at maximum output) than peak load
  - Normal operating condition: net importer of power



# Zone 2 system conditions

---

## ■ 2006

- Low voltages in west side from Conover to Ontonagon
- Low voltages in far eastern area
- Severely limited import capability from Wisconsin

## ■ 2010

- Same problems as in 2006, but worse if planned and proposed projects are not completed
- Cranberry-Conover-Plains improves voltages and reliability
- Hiawatha-Pine River-Mackinac (Straits) and Hiawatha-Indian Lake improves area voltages
- Various Zone 4 projects significantly improve import capability





# Zone 2 system conditions

---

- **2014**
  - Poor condition and system reliability issues requires rebuild of two 69 kV lines to 138 kV operation
  - Higher than expected load growth could require additional capacitor projects at Hiawatha, M38 and Empire Substations
  - Blaney Park-Munising rebuild/conversion addresses overloads and voltages in Central UP
  - Chalk Hills-Chandler rebuild/conversion improves reliability and diversifies ties between Zone 2 and Zone 4



# Zone 2

## 35+ projects 2005-2015

---

### Most notable projects include:

#### Planned

- 1 Stiles-Amberg 138 kV line rebuild (2006)
- 2 String second Hiawatha-Indian Lake circuit and convert both to 138 kV (2006/2009)

#### Proposed

- 5 Cranberry-Conover 115 kV line and Conover-Iron River-Plains rebuild and conversion to 138 kV (2008)

#### Provisional

- 6 Hiawatha-Pine River-Mackinac (Straits) 69 kV line rebuild and conversion to 138 kV (2009)
- 7 Blaney Park-Munising 69 kV line rebuild and conversion to 138 kV (2012)

## Zone 3 – Southern Wis./Northern Ill.

---

- **Growth projections**
  - Population: 0.8% from 2005-2010
  - Employment: 1.5% from 2005-2010
- **Environmental considerations**
  - Wetlands, major rivers, numerous lakes
- **Electricity demand and generation**
  - Expected load growth: 3.3% from 2006-2014; higher in Madison area
    - 2006 peak load is 3,290 MW
  - More generation (at maximum output) than peak load
  - Normal operating condition: net importer of power

# Zone 3 system conditions

---

## ■ 2006

- Low voltages, especially in Madison area, and transmission facility overloads identified through out area are current and emerging concerns
- Higher than average load growth in Rock and Walworth counties
- Intact system is supported by new generation on the UW Campus
- A substantial amount of power is imported into Dane County

## ■ 2010

- Same problems as in 2006, but worse if planned and proposed projects are not completed
- North Madison-Waunakee 138 kV line addresses cascading overloads in the Madison Area
- Stony Brook-Jefferson line along with the Rockdale-Mill Road 345 kV line addresses voltage problems and line overloads in Jefferson County
- N. Lake Geneva-White River-S. Lake Geneva 138 kV project will temporarily improve voltages in southwest Zone 3



# Zone 3 system conditions

---

## ■ 2014

- Widespread voltage collapse in Madison area a concern
- Low voltages on 69 kV and 138 kV in Wisconsin Dells area
- Low voltages at/near Richland Center and along 69 kV line from Gran Grae to Lone Rock requires reinforcement
- West Middleton-Rockdale 345 line along with additional 138 kV lines addresses serious voltage problems in Dane County
- Lake Delton-Birchwood 138 kV line addresses voltages and reliability for Wisconsin Dells area load
- Eden-Muscoda-Richland Center 69 kV line and Eden-Hillman voltage conversion addresses widespread voltage problems in southwest Wisconsin

# Zone 3

## 90+ projects 2005-2015

---



### Most notable projects include:

#### Planned

- 3 Convert Columbia-North Madison 138 kV line to 345 kV (2006)
- 4 Femrite-Sprecher 138 kV line 138 kV (2007)

#### Proposed

- 5 Jefferson-Lake Mills-Stony Brook 138 kV line (2007)
- 6 Rubicon-Hustisford-Horicon 138 kV line (2008)
- 7 North Madison-Waunakee 138 kV line (2008)
- 10 Rockdale West Middleton 345 kV line (2011)

#### Provisional

- 12 N. Lake Geneva-White River-S. Lake Geneva 138 kV line (2009)
- 13 Lake Delton-Birchwood 138 kV line (2011)
- 15 Eden-Muscoda-Richland Center 69 kV line (2012)
- 17 Twin Lakes-Spring Valley 138 kV line (2013)

## Zone 4 – Northeast Wisconsin

---

- Growth projections
  - Population: 0.8% from 2005-2010
  - Employment: 1.2% from 2005-2010
- Environmental considerations
  - Major lakes: Michigan and Winnebago
  - State forests and Horicon National Wildlife Refuge
- Electricity demand and generation
  - Expected load growth: 2.5% from 2006-2014
    - 2006 peak load is 3,251 MW
  - More generation than peak load
  - Net exporter during lighter load periods

# Zone 4 system conditions

---

## ■ 2006

- Green Bay area is severely congested
- Voltage problems in Door County
- Severely limited import capability between Wisconsin and Upper Peninsula

## ■ 2010

- Low import capability into Manitowoc area
- Morgan-Werner West provides an “electrical bypass” of Green Bay relieving the overloaded facilities (2009)
- Canal-Dunn Road 138 kV improves Door County voltages, but not completely (2008)
- Stiles-Amberg double circuit 138 kV line rebuild addresses facilities in poor condition and transfer capability between Wisconsin and Upper Peninsula (2006)





# Zone 4 system conditions

---

- **2014**
  - Continuing voltage problems in Door County
  - Dunn Road-Egg Harbor 69 kV line further improves Door County voltage problems (2010)
  - Pulliam-Suamico-Sobieski-Pioneer 69 kV rebuild and 138 kV conversion projects address facility overloads, load serving issues and facilities in poor condition (2008/2015)



# Zone 4

## 40+ projects 2005-2015

---

- Most notable projects include:

### Planned

- 3 Werner West 345/138 kV Substation (2006)
- 4 Stiles-Amberg double circuit 138 kV line rebuild (2006)
- 5 Morgan-Werner West 345 kV line & Clintonville-Werner West 138 kV line (2009)

### Proposed

- 6 Canal-Dunn Road 138 kV line (2008)
- 7 Dunn Road-Egg Harbor 69 kV line (2010)

### Provisional

- 8 Pulliam-New Suamico 69 kV line rebuild & conversion to 138 kV
- 13 New Suamico-Pioneer 69 kV line rebuild & conversion to 138 kV (2015)

## Zone 5 – Southeast Wisconsin

---

- Growth projections
  - Population: 0.5% from 2005-2010
  - Employment: 1.0% from 2005-2010
- Environmental considerations
  - Most densely populated zone
  - Agricultural land use is common
  - Lake Michigan, major rivers and Kettle Moraine State Forest
- Electricity demand and generation
  - Expected load growth: 1.6% from 2006-2014
    - 2006 peak load is 4,728 MW
  - More generation than peak load
  - Net exporter during lighter load periods

# Zone 5 system conditions

---

## ■ 2006

- Continued load growth in Waukesha, Washington and Jefferson counties driving need for voltage support
- New generation in greater Milwaukee area will drive many system improvements within next decade
- Waukesha-Duplainville-Sussex 138 kV line constructed in 2005 addresses load serving and voltage support issues in Sussex area

## ■ 2010

- Weak 138 kV network in Waukesha, Washington, and Jefferson needs support
- Cornell-Range Line and St. Lawrence-Pleasant Valley-Saukville 138 kV line rebuild addresses facility condition and overloads related to new generation at Port Washington (2008)
- Looping Ramsey-Harbor 138 kV line into Kansas and Norwich substations creating Kansas-Harbor and Ramsey-Norwich lines relieves overloads related to new generation at Oak Creek (2009)

# Zone 5 system conditions

---

- **2014**
  - Transmission additions and modifications required by new Port Washington and Oak Creek generation projects removed most overloads and low voltages seen in 2006 and 2010
  - Twin Lakes-Spring Valley line will improve the Lake Geneva area and provide support to the far southwest part of Zone 5 (2013)
  - Rockdale-Concord-Bark River-Mill Road 345 kV line along with Bark River and Concord substation expansions for 345 kV facilities and 345/138 kV transformation addresses (2011)
    - Voltage profiles in Jefferson, Waukesha and Washington counties
    - Reduces loading on weak parallel 138 kV network
    - Reduces system losses and
    - Increases east-west transfer capability



# Zone 5 projects

## 30+ projects 2005-2015

---

- Most notable projects include:

### Planned

- 1 Cornell-Range Line and St. Lawrence-Pleasant Valley-
- 2 Saukville 138 kV line reconductor (2008)
- 3 Expand 345/230/138 kV Substations at Oak Creek (2009)
- 4 Convert Bark River-Mill Road 138 kV line to 345 kV (2011)

### Proposed

- 5 Expand Hale (Brookdale) Substation (2013)
- 6 Loop Zion-Arcadian 345 kV line into Pleasant Prairie Substation (2013)
- 7 Oak Creek-Hale-Granville 345 kV line (2013)

# Major projects in design or under construction



<i><b>Project</b></i>	<i><b>Area</b></i>
Arrowhead-Gardner Park (Weston) 345 kV line	Zone 1
Gardner Park (Weston) 345/115 kV Substation	Zone 1
Rebuild and convert one Hiawatha-Indian Lake 69 kV line to double circuit 69 kV	Zone 2
Convert Columbia-N. Madison 138-kV to 345 kV operation	Zone 3
Uprate North Appleton-Rocky Run 345 kV line	Zone 4



# Major projects fully approved by PSC

---

<b><i>Project *</i></b>	<b><i>Area</i></b>
N. Beaver Dam-E. Beaver Dam 138 kV line	Zone 3
Sprecher-Femrite 138 kV line	Zone 3
Turtle-Bristol 69 kV line rebuild to 138 kV and operated at 69 kV	Zone 3
Werner West 345/138 kV substation	Zone 4
<i>* Approved but not yet under construction</i>	



# Major projects awaiting regulatory approval



<i><b>Project</b></i>	<i><b>Area</b></i>
Gardner Park-Central Wisconsin 345 line	Zone 1
West-Serman St.-Hilltop 115 kV line to double-circuit 115 KV	Zone 1
Cranberry-Conover 115 kV line and rebuild/convert Conover-Plains to 138 kV operation	Zone 1&2
Jefferson-Lake Mills-Stony Brook 138 kV line	Zone 3
Morgan-Werner West 345 kV line and Werner West-Clintonville 138 kV line	Zone 4

# Major projects eliminated



Projects Cancelled	Former In-service date	Planning Zone	Reason for Removal
Reconfigure 345 kV bus at Pleasant Prairie	2006	5	Another alternative selected (Bain)
Install two 345 kV series breakers at Pleasant Prairie on lines to Racine and Zion	2009	5	Oak Creek Study Results
Replace 138 kV over-dutied breakers at Bluemound SS	2009	5	Oak Creek Study Results
Expand 345 kV switchyard at Bain Substation and string Bain-Racine 345 kV circuit	2012	5	Oak Creek Study Results
Replace 22 138 kV over-dutied breakers at Harbor, Everett and Haymarket substations	2014	5	Oak Creek Study Results

# Cost estimates

## *Estimated capital costs*



	2004*	2005
	<u>TYA</u>	<u>TYA</u>
▪ Asset renewal	\$163	\$238 Million
▪ Generation interconnections	\$167	\$339 Million
▪ Distribution interconnections	\$242	\$234 Million
▪ Infrastructure relocation	\$3	\$4 Million
▪ Network	\$2143	\$2411 Million
▪ Protection and control	<u>\$87</u>	<u>\$83</u> Million
▪ <b>Total</b>	<b>\$2.8</b>	<b>3.4 Billion</b>
▪ <b>Total for projects in TYA</b>	<b>\$2.1</b>	<b>2.4 Billion</b>

\* Values same in 2004 TYA Update

# Reasons for cost increases

---

- Increases in the cost of steel and construction labor
- Revisions to planned, proposed and provisional projects based on current analyses
- Start-up of new, large projects



# Project prioritization index: factors considered

---

- Safety/service restoration
- System reliability/security
- Regulatory mandates
- Load serving/interconnection
- Transaction limit alleviation
- Strategic expansion
- Infrastructure update
- In-service date
- Cascading outage
- Equipment damage/loss of load
- Reduced redispatch/transmission load relief mitigation



# Transmission Business Briefing

---

Questions?



---

# 2005 Transmission Business Briefing